



# Wind and Solar PV Resource Aggregation Study for South Africa

Public presentation of results



Pretoria, 3 March 2016

Dr. Stefan Bofinger, Britta Zimmermann, Ann-Katrin Gerlach – Fraunhofer IWES  
Dr. Tobias Bischof-Niemz, Crescent Mushwana – CSIR

REV 1

# Acknowledgements and contributions



Working group:

**SAWEA**

**SAPVIA**

**DoE IPP Office**

**GIZ SAGEN**

**DoE**

**DANIDA/DoE**

**Energy Exemplar**

Study was conducted from early 2015 to March 2016

REV 1



# Executive Summary

**CSIR, SANEDI, Eskom and Fraunhofer IWES conducted a study to holistically quantify**

- the wind-power potential in South Africa and
- the portfolio effects of widespread spatial wind and solar power aggregation in South Africa

**Wind Atlas South Africa (WASA) data was used to simulate wind power across South Africa**

**Key result: South Africa exhibits world-class conditions to introduce very large amounts of variable renewables into the electricity system**

- Both solar and wind resources are world class: solar PV and wind turbines are therefore very low-cost bulk energy providers in South Africa already today
- Both solar and wind supply have very low seasonality in South Africa
- Very wide-spread interconnected electricity grid enables spatial aggregation to reduce volatility
- South Africa is a very large country with low population density: space is not a constraint
- Turbines widely dispersed: Even 50% wind energy share does not create short-term volatility

REV 1

# Agenda

1. Introduction
2. Data
3. Methodology
4. Scenarios
5. Results
6. Conclusions and Outlook

# Agenda

## 1. Introduction

I. Fraunhofer IWES

II. CSIR Energy Centre

III. Motivation

IV. Objectives of the study

2. Data

3. Methodology

4. Scenarios

5. Results

6. Conclusions and Outlook

# Fraunhofer Institute for Wind Energy and Energy System Technology (Fraunhofer IWES)

## Main Research:

- Wind energy from material development to grid optimization
- Energy system technology for all renewables

## ■ Fraunhofer IWES | Kassel

Director: Prof. Dr. Clemens Hoffmann

## ■ Fraunhofer IWES | Northwest

Director: Prof. Dr. Andreas Reuter

■ **Annual budget:** approx. EUR 30 millions

■ **Staff:** approx. 500



REV 1

# Fraunhofer IWES


## Energy System Technology, Kassel

R&D for the success of the German „Energiewende“ and the global use of renewable energy




REV 1

# Core Skills for Energy System Technology



REV 1

# Introduction IWES – Kassel Site: Energy System Technology



REV 1

# IWES team

## Project lead and management

- Scientific supervision
- Curtailment
- Skills exchange



Dr. Stefan Bofinger



Britta Zimmermann

- Case study I
- Results analysis
- Skills exchange



Kaspar Knorr

- Data processing
- Spatial distribution
- Aggregation of time series



Ann-Katrin Gerlach

- Data processing
- Wind time series
- Skills exchange



Mirjam Stappel

- Data processing
- PV time series



Rainer Schwinn

- Demand



Jan Dobschinski

- Forecast

# Agenda

## 1. Introduction

- I. Fraunhofer IWES
- II. CSIR Energy Centre
- III. Motivation
- IV. Objectives of the study

## 2. Data

## 3. Methodology

## 4. Scenarios

## 5. Results

## 6. Conclusions and Outlook


# South Africa's Council for Scientific and Industrial Research (CSIR)

The CSIR's Executive Authority is the Minister of Science and Technology

The CSIR is a science council, classified as a national government business enterprise, with six sites across South Africa, headquartered in Pretoria

## The CSIR in numbers

- 70 years (established 5 October 1945)
- Close to 3 000 total staff
- ...of which 1 700 scientists, engineers & technologists
- ...of which more than 300 doctoral qualifications
- 8 research centres/units, three implementation units
- ~ \$200 million total operating income per year  
(~30% government grant to invest into new topics, ~70% through contract research)



# CSIR's six Research Impact Areas (RIAs) respond to the priorities as defined by South Africa's "National Development Plan (NDP)"

## Core technologies & facilities

Materials

Sensors

Photonics

Robotics

ICT

Modelling

Research facilities



# CSIR's new Energy Centre streamlines and expands CSIR's energy research offerings in five areas – today: 20 staff members, growing

Potentially 6<sup>th</sup>  
area: Industry  
Business Cases

## CSIR Energy Centre research areas

### Energy Efficiency & Demand Response

- Energy Efficiency in all end-use sectors
- Demand forecasting
- Demand response
- Energy statistics

### Renewable Energy Technologies

- Solar
- Wind
- Biomass/-gas
- Liquid Biofuels
- Small Hydro
- Ambient Heat

### Energy Storage and Hydrogen

- Energy Storage (Power-to-Power, Power-to-Heat)
- Power-to-Hydrogen
- Power-to-Gas
- Power-to-Liquids
- Electric Mobility

### Energy-System Planning & Operations

- Energy Planning
- Grid Planning
- Micro and Island Grids
- System Operations
- Smarter Grids

### Energy Markets and Policy

- Macro- and Energy Economics
- Clean Energy Markets (RE and Natural Gas)
- Regulatory Environment and Market Design

CSIR Energy-Autonomous Campus  
(cross-cutting demonstration programme)

Five year objective: approx. 100-120 staff to be able to address all relevant dimensions of RSA's energy transition



REV 1

# The CSIR Energy Centre's vision and mission

## Vision


“To provide the knowledge base for the South African energy transition and beyond”

## Mission

The Energy Centre's activities are guided by the desire to help developing a sustainable energy system, more specifically:

- To conduct directed research in emerging energy technologies and system integration
- To prove the concept of emerging energy technologies and of integrated energy systems
- To demonstrate energy technologies and systems in the South African context and to support their commercialization
- To conduct directed research towards the understanding of how to optimally design, build and operate cost efficient, reliable and sustainable energy systems
- To find optimal pathways for the expansion and operation of energy systems through modelling and simulation
- To advise policymakers on market design and regulatory concepts for the integration of new energy technologies
- To provide support for South African industries on key energy-system-related decisions
- To provide thought leadership for the energy research agenda in South Africa and in the region
- To be globally recognised as the premier applied-energy-research organisation on the African continent

# CSIR Energy Centre team as of 7 March 2016



REV 1

# Agenda

## 1. Introduction

- I. Fraunhofer IWES
- II. CSIR Energy Centre
- III. Motivation
- IV. Objectives of the study

## 2. Data

## 3. Methodology


## 4. Scenarios

## 5. Results

## 6. Conclusions and Outlook

# Africa has some of the best solar resources worldwide

**VAISALA**




© 2013 Vaisala Inc.

REV 1

# Southern Africa also has some of the best wind resources


**VAISALA**



REV 1

# South Africa has almost two times the solar resource of Germany, where solar PV is close to cost competitiveness

Solar resource in South Africa...



SA's planned PV capacity by 2030: 8.4 GW

... as compared to Germany





Germany's status today: almost 40 GW installed solar PV capacity (roughly one Eskom)

REV 1

# Best wind sites in Germany along the coastline have similar wind speeds as large parts of inland South Africa (yellow)

Wind resource in South Africa...

... as compared to Germany



SA's planned wind capacity by 2030: 9.2 GW


Germany's status today: almost 46 GW installed wind capacity (roughly one Eskom)

REV 1

# In less than two years, South African PV has outpaced the US


2013

Share of solar PV in electricity production



2015

Share of solar PV in electricity production




Sources: EIA; CSIR

REV 1

# Even within a small area around Port Elizabeth, aggregation effect for both solar PV and wind power output clearly visible

21 September 2011: Simulated output for five individual wind and PV sites and for entire PE region



REV 1

# Contents

## 1. Introduction

I. Fraunhofer IWES

II. CSIR Energy Centre

III. Motivation

IV. Objectives of the study

2. Data

3. Methodology

4. Scenarios

5. Results

6. Conclusions and Outlook

# Objectives of the study

**Main goal: Increase the fact base and understanding of aggregated wind and solar PV power profiles for different spatial distributions of wind turbines in South Africa**

- Generate data sets that can be used for various studies (IEP, IRP, TDP, SEA etc.)
- Transfer of knowledge and skills on utilising wind data in energy-planning activities




## Resulting in

- Confidence in integrating higher RE shares
- Basis for further research, e.g. defining an optimal RE mix, system adequacy & reserve margin


**The study was conducted from early 2015 to March 2016 and covers whole of South Africa**

- Wind and solar data sets covering the entire country
- 5x5 km spatial resolution, 15 minute time resolution, 5 years of data
- Spatial load data for the entire country


REV 1



## WIND AND SOLAR AGGREGATION STUDY SOUTH AFRICA



# Publications issued during the course of the study



REV 1

# Contents

1. Introduction
2. **Data**
3. Methodology
4. Scenarios
5. Results
6. Conclusions and Outlook


# Raw data: time- and spatially synchronous wind and solar data produced from reliable raw-data sources (WASA&SODA)

Model name	WASA	SODA
Variables	Wind speed, temperature	Solar irradiation
Height	50 m, 80 m, 100 m, 150 m (v) 2 m (T)	-
Temporal coverage	2009 to 2013	2010 to 2012
Temporal resolution	15 min	15 min
Spatial coverage	South Africa	South Africa
Spatial resolution	5 km x 5 km	0.2° x 0.2° (similar to 5 km x 5 km)

REV 1


# South Africa has wide areas with > 6 m/s average wind speed

Average wind speed at 100 meter above ground for the years from 2009-2013 for South Africa




REV 1


# Validation: Is a 5x5 km<sup>2</sup> resolution of weather data sufficiently high for the purposes of this aggregation study?




approximate pixel distance: 50km



approximate pixel distance: 100km



approximate pixel distance: 150km




approximate pixel distance: 350km

- Evaluating simulation results (= feed-in)
- Step 1: Considering every pixel
- Step 2: Considering every second pixel
- Step 3: Considering every third pixel
- ...

REV 1


# Fluctuations of aggregated wind power stay constant below 50 km pixel distance → resolution of 5x5 km high enough



Results for different starting pixels

REV 1

# Fluctuations of 15-min ramps of aggregated wind power stay constant below 20 km pixel distance → 5x5 km sufficient



- Resolution below 20x20 km<sup>2</sup> seems to be sufficient for a nation-wide study
- For actual plant design and techno-economical viability studies higher resolution data could be necessary

REV 1


# Demand: Historical spatially available load data scaled to match estimated future country demand of 500 TWh/yr

## Raw data used (source: Eskom)

- Historical data for entire country
- Spatially distributed across transmission substations (present:2014 and future: 2024)
- Temporal coverage: years from 2010-2012
- Temporal resolution: 30 min but (interpolated to an 15-min resolution to match solar/wind data)
- Current total country demand: ~225 TWh/yr

## Future estimated demand: 500 TWh/yr

→ Scaled on demand of single grid Nodes and allocated to grid nodes




REV 1

# Contents

1. Introduction
2. Data
- 3. Methodology**
4. Scenarios
5. Results
6. Conclusions and Outlook






# Core study approach: Simulated wind/PV and historical load jointly analysed



REV 1

# Generic wind turbines defined with applicability for different wind-speed regimes: basis for wind farm design per pixel


Space requirement 0.1 km<sup>2</sup>/MW  
 → max. 250 MW per pixel



Turbine type no.	1	2	3	4	5
Nominal power	3 MW	2.2 MW	2.4 MW	2.4 MW	2.4 MW
Rotor diameter	90 m	95 m	117 m	117 m	117 m
Swept rotor area	6 362 m <sup>2</sup>	7 088 m <sup>2</sup>	10 750 m <sup>2</sup>	10 750 m <sup>2</sup>	10 750 m <sup>2</sup>
Power per swept area	442 W/m <sup>2</sup>	310 W/m <sup>2</sup>	223 W/m <sup>2</sup>	223 W/m <sup>2</sup>	223 W/m <sup>2</sup>
Hub height	80 m	80 m	100 m	120 m	140 m
Selection criterion	∅v @ 80 m > 8.5 m/s	∅v @ 80 m < 8.5 m/s and ∅v @ 100 m > 7.5 m/s	∅v @ 100 m < 7.5m/s	∅v @ 120 m < 7.5 m/s	∅v @ 140 m < 7.5 m/s
Turbine type	High wind speed	Medium wind speed	Medium to low wind speed	Low wind speed	Low wind speed


REV 1

In each of the 50 000 pixels of 5x5 km size across the country, a wind farm placed consisting of turbines of type 1, 2, 3, 4 or 5




REV 1

# Power curves of single wind turbines (top) and for simulated wind farms on a 5km x 5km pixel (bottom) by turbine type




Wind turbine characteristic as taken from data sheets



For considering wind farm effects (shading, wake) as well as simulating the aggregation / smoothing within the 5x5 km<sup>2</sup> areas, smoothed wind turbine power curves defined and applied per pixel


REV 1

# Generation of time series of wind feed-in



# Share of each 5x5 km<sup>2</sup> pixel that is suitable for installation of wind farm after excluding areas reserved for other functions

Exclusion masks sourced from the Department of Environmental Affairs's Wind and solar PV REDZ study (conducted by the CSIR)




Note: Within the Mpumalanga area (dark red area in the map) data are incomplete. Therefore larger areas are assumed to be suitable. In reality, more exclusion areas will be found. Due to the low wind resources in the Mpumalanga area the impact on the final results should be insignificant.

REV 1

# Definition:

“Residual load” needs to be supplied by dispatchable power

$$\text{Residual load } (t) = \text{Load } (t) - \text{PV feed-in } (t) - \text{Wind feed-in } (t)$$



REV 1

# Agenda

1. Introduction
2. Data
3. Methodology
- 4. Scenarios**
5. Results
6. Conclusions and Outlook

# Three solar PV and three wind penetration levels defined

Overview of combination of solar PV and wind scenarios; load scaled to 500 TWh/yr total electricity

Solar PV energy penetration (one fixed spatial distribution defined)	Wind energy penetration			
		50 TWh/yr (~15 GW)	100 TWh/yr (~30 GW)	250 TWh/yr (~75 GW)
	<b>40 TWh/yr</b> (~21 GWp)	<ul style="list-style-type: none"> <li>VRE Share: 18%</li> <li>9 Wind distribution scenarios</li> </ul>	<ul style="list-style-type: none"> <li>VRE Share: 28%</li> <li>9 Wind distribution scenarios</li> </ul>	<ul style="list-style-type: none"> <li>VRE Share: 58%</li> <li>9 Wind distribution scenarios</li> </ul>
	<b>80 TWh/yr</b> (~42 GWp)	<ul style="list-style-type: none"> <li>VRE Share: 26%</li> <li>9 Wind distribution scenarios</li> </ul>	<ul style="list-style-type: none"> <li>VRE Share: 36%</li> <li>9 Wind distribution scenarios</li> </ul>	<ul style="list-style-type: none"> <li>VRE Share: 65%</li> <li>9 Wind distribution scenarios</li> </ul>
<b>200 TWh/yr</b> (~104 GWp)	<ul style="list-style-type: none"> <li>VRE Share: 44%</li> <li>9 Wind distribution scenarios</li> </ul>	<ul style="list-style-type: none"> <li>VRE Share: 52%</li> <li>9 Wind distribution scenarios</li> </ul>	<ul style="list-style-type: none"> <li>VRE Share: 75%</li> <li>9 Wind distribution scenarios</li> </ul>	

Load for all scenarios:  
500 TWh/yr

Note: VRE = variable renewable energy, which is solar PV and wind (the only two variable power sources; dispatched by the weather and not be the owner / system operator)  
VRE share is calculated on the basis of „useful VRE per total electricity demand“, i.e. curtailed VRE is not considered in these numbers

REV 1

# Scenarios: for each wind-energy penetration level 9 scenarios of different spatial distribution of the wind fleet are tested

## 'Scientific' scenarios

- 1a Uniform wind turbine distribution
- 1b All-in-one-place
- 1c High wind speeds wind turbine distribution
- 1d Minimal ramps wind turbine distribution

## Designated areas investigated

- 2a EIA<sup>1</sup>-focused wind turbine distribution
- 2b REDZs<sup>2</sup>-focused wind turbine distribution
- 2c EIA/REDZs overlaps

## Grid-oriented scenarios

- 3a Current grid-focused wind turbine distribution
- 3b Future grid-focused wind turbine distribution

1. Environmental Impact Assessment areas

2. Renewable Energy Development Zone


REV 1

# Present and future grid nodes for grid-oriented scenarios and the individual location selected for 'All-in-one-place' scenario

1b

3a


3b



REV 1


# Areas used for the designated-areas scenarios

- 2a
- 2b
- 2c



REV 1

# In order to achieve 50, 100, 250 TWh/yr of wind electricity, ~15 GW / ~30 GW / ~75 GW of wind power need to be installed




→ 50 TWh/yr of wind electricity requires 1 500 km<sup>2</sup> = 0.12% of South Africa's landmass

→ 250 TWh/yr of wind electricity requires 7 500 km<sup>2</sup> = 0.61% of RSA's landmass

REV 1

# Only a small portion of wind farm area is actually utilised land


Illustration of space consumed by wind farms in a 250 TWh/yr wind energy scenario



REV 1

# During construction, actual land used is already low


Illustration of land required during construction of a wind farm



REV 1

# During wind farm operation, the land actually used is very low

Illustration of land required during operation of a wind farm



	% of the wind farm area	% of South African land mass (for a 75 GW wind fleet that yields 250 TWh/yr)
Wind farm area	100%	0.61% (7 500 km <sup>2</sup> )
Ways, foundation during construction	3%	0.018% (225 km <sup>2</sup> )
Permanently used	2%	0.012% (150 km <sup>2</sup> )
Wind turbine foundations	0.1%	0.0008% (10 km <sup>2</sup> )

REV 1

# The total solar PV potential in South Africa from distributed installations & utility-scale in already applied EIAs is 300 GW

## Distributed solar PV (rooftop only)


- 73 GW installed capacity
- 136 TWh/yr electricity generation

## Utility-scale solar PV (in EIAs only)

- 220 GW installed capacity
- 420 TWh/yr electricity generation

## Total potential (rooftop and EIAs only)

- 292 GW installed capacity
- > 550 TWh/yr electricity generation



## Additional potential: distributed small and medium ground-mounted

Note: The potential for distributed solar PV is based on very conservative estimates for achievable penetration with rooftop solar PV in settlement areas. It is assumed that 10% of the total settlement area are rooftops which can in principle be used for solar PV. The potential needs to be further quantified in subsequent studies.

REV 1

# Solar PV defined as a mix of distributed and utility-scale

- 70% of the annual electricity is generated by distributed solar PV installations
- 30% of the annual electricity is generated by large, utility-scale installations

	Penetration level 1	Penetration level 2	Penetration level 3
	40 TWh/yr	80 TWh/yr	200 TWh/yr
Distributed (70%)	15 GW	29 GW	73 GW
Utility scale (30%)	6 GW	13 GW	31 GW
<b>Total</b>	<b>21 GW</b>	<b>42 GW</b>	<b>104 GW</b>

1. „Distributed” is a proxy for all PV that is assumed to be distributed according to population density. It represents all PV close to the load which in this study would include only rooftop PV in all sizes. In reality, distributed PV could also include small ground-mounted installations.

2. “Utility-scale” is a proxy for large-scale PV installations in the multi-MWp-range, for which EIAs have been applied for.

REV 1

# Agenda

1. Introduction
2. Data
3. Methodology
4. Scenarios
- 5. Results**
  - I. Case Study Supply Area Port Elizabeth
  - II. Aggregation Study
  - III. Case Study Curtailment
6. Conclusions and Outlook


REV 1

# Case study: Supply areas of South Africa

The South African transmission grid is divided into 27 supply areas

Each supply area comprises several grid nodes


The size of the supply areas is determined by the total customer load



→ Supply areas with load centres usually include a high number of nodes in a small area

REV 1


# Case study: Aggregation effects within the supply area of Port Elizabeth



REV 1

# Case study: Spatial aggregation smoothens volatility


Simulated supply of 5 solar, 5 wind farms & of the entire Port Elizabeth area on 21 March 2011



REV 1

# Case study: Spatial aggregation smoothens volatility


Simulated supply of 5 solar, 5 wind farms & of the entire Port Elizabeth area on 21 June 2011



REV 1

# Case study: Spatial aggregation smoothens volatility


Simulated supply of 5 solar, 5 wind farms & of the entire Port Elizabeth area on 21 September 2011



REV 1

# Case study: Spatial aggregation smoothens volatility

Simulated supply of 5 solar, 5 wind farms & of the entire Port Elizabeth area on 21 December 2011



REV 1

# Contents


1. Introduction
2. Data
3. Methodology
4. Scenarios
- 5. Results**
  - I. Case Study Supply Area Port Elizabeth
  - II. Aggregation Study**
  - III. Case Study Curtailment
6. Conclusions and Outlook

REV 1

# Solar PV monthly supply has very low seasonality, wind supply more in winter: correlated to the load

Simulated solar PV, wind, scaled load – grid-focused wind distribution: 250 TWh/yr, PV: 80 TWh/yr

Energy in TWh/month




→ PV: nearly no seasonality

→ Monthly wind supply is correlated with the monthly fluctuations in demand

REV 1

# Average wind profile generally with less output during the day and more during evening/night – complements well load & PV


Simulated solar PV, wind, scaled load – grid-focused wind distribution: 250 TWh/yr, PV: 80 TWh/yr



REV 1


# Average wind profile generally with less output during the day and more during evening/night – complements well load & PV

Simulated solar PV, wind, scaled load – grid-focused wind distribution: 250 TWh/yr, PV: 80 TWh/yr



REV 1


**Definition of load factor: Total energy produced during a time period divided by (nominal power multiplied by time period)**



$$\frac{\text{[Yellow Box]}}{\text{[Yellow Box] + [Hatched Box]}} = \text{LF PV}$$

REV 1


**Definition of load factor: Total energy produced during a time period divided by (nominal power multiplied by time period)**



$$\frac{\text{[Blue Box]}}{\text{[Blue Box]} + \text{[Hatched Box]}} = \text{LF wind}$$

REV 1


# Placing a wind farm of best suited turbine type (1, 2, 3, 4 or 5) in each pixel: more than 30% load factor almost everywhere



→ Very high load factors of >30% nearly all over the country!

REV 1

# Even when placing only high-wind-speed turbine types (1, 2, 3) in each pixel: more than 30% load factor in very wide areas




→ Very high load factors of >30% nearly all over the country even for turbines types 1-3

REV 1

# On almost 70% of suitable land area in South Africa a 35% load factor or higher can be achieved (>50% for turbines 1-3)

Share of South African land mass less exclusion zones with load factors to be reached accordingly




→ Installing turbine type 4 and 5 will cause higher costs but also increase load factors and electricity yield whilst consuming the same area

REV 1

# Achievable load factors in all turbine categories significantly higher than actual load factors in leading wind countries

Load factors by turbine type across all 50 000 pixels for South Africa for years 2009-2013

- Years: 2009-2013




REV 1

# A single wind farm changes its power output quickly

Simulated wind-speed profile and wind power output for 14 January 2012

14 Jan 2012 23:45 SAST



wind speed at 100m above ground



Fraunhofer  
IWES



Aggregation level: 0  
Number of wind pixel: 1



REV 1


# Aggregating just 10 wind farms' output already reduces short-term fluctuations

Simulated wind-speed profile and wind power output for 14 January 2012


14 Jan 2012 23:45 SAST






wind speed at 100m above ground



Aggregation level: 1  
Number of wind pixel: 10



Aggregation level: 0  
Number of wind pixel: 1



REV 1


# Aggregating 100 wind farms: 15-min gradients almost zero

Simulated wind-speed profile and wind power output for 14 January 2012


14 Jan 2012 23:45 SAST






wind speed at 100m above ground



Aggregation level: 2  
Number of wind pixel: 100



Aggregation level: 1  
Number of wind pixel: 10



REV 1


# Aggregation across entire country: wind output very smooth

Simulated wind-speed profile and wind power output for 14 January 2012


14 Jan 2012 23:45 SAST






wind speed at 100m above ground



Aggregation level: 3  
Number of wind pixel: 43113




Aggregation level: 2  
Number of wind pixel: 100



REV 1

# In all scenarios, achievable load factors are very high




- Very high load factors for all scenarios
- „Minimal ramps“ optimization leads to lower ramps but also to lower load factors

REV 1

# Wide spatial wind distribution leads to smooth duration curve

Aggregated wind power duration curves for different scenarios for years 2010-2012




- Wider distribution leads to smoother wind-power duration curves
- With a wider distribution there is residual electricity feed-in at all times

REV 1

# Excess energy only occurs with very high wind penetration

Duration curves of residual load for “grid-focused wind turbine distribution” for different penetrations




- Wind feed-in reduces the residual load at almost every moment
- Electricity surplus occurs at very high wind penetration only

REV 1

# Solar PV: excess steeply increases above certain penetration

Duration curves of residual load for “grid-focused wind turbine distribution” for different penetrations




→ High PV shares leads to high electricity surpluses

→ Base load disappears

REV 1

# Max. residual load significantly lower than max. system load

Maximum residual load for different scenarios with PV: 80 TWh and different wind penetration levels



→ A higher installed capacity decreases maximum residual load


→ Installed capacity of PV does not have an influence

REV 1

# Spatial distribution reduces 15-minute gradients drastically

Relative frequency of 15-min gradients of residual load for different wind spatial distribution


- 100 TWh of electricity from wind energy and 40 TWh from PV



REV 1

# Short-term fluctuations of residual load quantified for different penetration with wind and solar PV


Standard deviation of 15-min gradients of residual load for different wind penetrations and scenarios



REV 1

# 15-min gradients do not increase with higher wind penetration


Standard deviation of 15-min gradients of residual load for different wind penetrations and scenarios



REV 1

# 15-min gradients do not increase with higher wind penetration


Standard deviation of 15-min gradients of residual load for different wind penetrations and scenarios



REV 1

# 15-min gradients do not increase with higher wind penetration

Standard deviation of 15-min gradients of residual load for different wind penetrations and scenarios



REV 1

# Findings of analysis of short-term fluctuations

## **PV is the main driver for 15-minute gradients in the residual load**

- This is due to the astronomical movement of the sun which causes bell-shaped output of solar PV in a clearly defined pattern every day
- These 15-minute gradients caused by solar PV exist, but are highly predictable (caused primarily by the highly predictable astronomical movement of the sun)

## **Adding wind energy does not increase the standard deviation of 15-min gradients**

**Higher overall shares of RE can be realized with low standard deviations as well but show a stronger dependency on the ratio of wind to PV**


**A share of up to ~30% of RE causes no significant increase in 15-minute gradients**

**Wind alone can provide 50% of the total energy demand without significant increase in the 15-minute gradients; the wind output changes are more low frequency over several hours**

REV 1

# Putting wind turbines in one place makes the supply volatile

Statistics of aggregated wind output and residual load for the “all-in-one-place” wind distribution




		Potential	50 TWh/yr	100 TWh/yr	250 TWh/yr	All in one place 100 TWh/yr
Capacity		0.16 GW	16 GW	32 GW	81 GW	32 GW
Minimum output		0 GW	0 GW	0 GW	0 GW	0 GW
Normalised wind power 15-min gradient	Max	92%	92%	92%	92%	92%
	Min	-91%	-91%	-91%	-91%	-91%
Residual load 15-min gradient	Max	5.5 GW	15 GW	30 GW	74 GW	30 GW
	Min	-3.1 GW	-15 GW	-30 GW	-74 GW	-30 GW
Daily energy	Max	3.5 GWh	354 GWh	708 GWh	1 769 GWh	708 GWh
	Mean	1.3 GWh	137 GWh	274 GWh	685 GWh	274 GWh
	Min	0 GWh	0.5 GWh	1.0 GWh	2.5 GWh	1 GWh

REV 1

# A uniform wind turbine distribution reduces 15-min gradients to +/- 4% of nominal installed wind capacity

Statistics of aggregated wind output and residual load for the uniform wind turbine distribution




		Potential	50 TWh/yr	100 TWh/yr	250 TWh/yr	All in one place 100 TWh/yr
Capacity		6 787 GW	16 GW	31 GW	78 GW	32 GW
Minimum output		162 GW	0.4 GW	0.8 GW	1.9 GW	0 GW
Normalised wind power 15-min gradient	Max	4.2%	4.2%	4.2%	4.2%	92%
	Min	-4.3%	-4.3%	-4.3 %	-4.3 %	-90%
Residual load 15-min gradient	Max	291 GW	5.4 GW	5.3 GW	4.7 GW	30 GW
	Min	-285 GW	-3.2 GW	-3.3 GW	-3.6 GW	-30 GW
Daily energy	Max	119 449 GWh	274 GWh	549 GWh	1 374 GWh	708 GWh
	Mean	59 494 GWh	137 GWh	274 GWh	685 GWh	274 GWh
	Min	13 327 GWh	31 GWh	61 GWh	153 GWh	1 GWh

REV 1

# A uniform wind turbine distribution reduces 15-min gradients to +/- 4% of nominal installed wind capacity

Statistics of aggregated wind output and residual load for the uniform wind turbine distribution

		Potential	50 TWh/yr	100 TWh/yr	250 TWh/yr	All in one place 100 TWh/yr
Capacity		6 787 GW	16 GW	31 GW	78 GW	32 GW
Minimum output		162 GW	0.4 GW	0.8 GW	1.9 GW	0 GW
Normalised wind power 15-min gradient						
Residual load 15-min gradient						
Daily energy						
	Mean	59 494 GWh	137 GWh	274 GWh	685 GWh	274 GWh
	Min	13 327 GWh	31 GWh	61 GWh	1 534 GWh	1 GWh




**This capacity would be sufficient to cover the entire world's electricity demand of about 20 000 TWh/yr!**

REV 1

# Putting wind turbines at high-wind-speed sites only leads to higher short-term gradients (+/- 8%) and low min output

Statistics of aggregated wind output and residual load for the “high-wind-speed” wind distribution




		Potential	50 TWh/yr	100 TWh/yr	250 TWh/yr	All in one place 100 TWh/yr
Capacity		6 787 GW	15 GW	30 GW	76 GW	32 GW
Minimum output		162 GW	0.01 GW	0.04 GW	0.08 GW	0 GW
Normalised wind power 15-min gradient	Max	4.2%	16%	12%	8.4%	92%
	Min	-4.3%	-17%	-12%	-8.5%	-91%
Residual load 15-min gradients	Max	292 GW	5.4 GW	5.9 GW	9.0 GW	30 GW
	Min	-286 GW	-3.3 GW	-4.3 GW	-5.7 GW	-30 GW
Daily energy	Max	119 450 GWh	301 GWh	603 GWh	1 539 GWh	708 GWh
	Mean	59 494 GWh	138 GWh	275 GWh	686 GWh	274 GWh
	Min	13 327 GWh	2.9 GWh	6.7 GWh	15 GWh	1 GWh

REV 1

# Wind turbine distribution to reduce 15-min-ramps: +/- 4%


Statistics of aggregated wind output and residual load for the “minimum gradients” wind distribution



		Potential	50 TWh/yr	100 TWh/yr	250 TWh/yr	All in one place 100 TWh/yr
Capacity		6 787 GW	17 GW	33 GW	82 GW	32 GW
Minimum output		162 GW	0.04 GW	0.16 GW	2.5 GW	0 GW
Normalised wind power 15-min gradient	Max	4.2%	10%	7.7%	4.5%	92%
	Min	-4.3%	-7.2%	-4.6%	-3.8%	-91%
Residual load 15-min gradient	Max	292 GW	5.2 GW	5.0 GW	4.6 GW	30 GW
	Min	-286 GW	-3.0 GW	-2.9 GW	-3.3 GW	-30 GW
Daily energy	Max	119 450 GWh	265 GWh	499 GWh	1 198 GWh	708 GWh
	Mean	59 494 GWh	137 GWh	274 GWh	685 GWh	274 GWh
	Min	13 327 GWh	32 GWh	84 GWh	247 GWh	1 GWh

REV 1


# South Africa is split into 27 supply areas – midpoints of these areas are used to measure distance and wind correlation



REV 1

# The further two wind farms are away from each other, the lower the correlation between their power-production profiles

Correlation of wind-power production between supply areas




REV 1


# Correlation of wind-power gradients is low for far distances

Correlation of 15-min and 1-hr gradients of wind-power production between supply areas

15 minutes gradients




1 hour gradients




REV 1

# Very high wind penetration (250 TWh/yr load): at times, electricity surpluses will occur (negative residual load)



REV 1

# The total amount of energy during periods of excess electricity gives an indication for bulk storage needs




- Electricity deficit can be provided by conventional or flexible power fleet
- Electricity surplus can either be curtailed or stored
- Longest period of continuous excess generation: 18-60 hours, depending on the spatial distribution of the wind fleet

REV 1

# Depending on the scenario, between 18-72 hours of continuous excess electricity can occur

Electricity surpluses: Maximum duration by scenario



REV 1

# Excess energy is mainly caused by high solar PV shares

Generated solar PV and wind energy and split into useful and excess for different VRE penetrations

## Low PV / low wind


Load: 500 TWh/yr  
 PV: 40 TWh/yr  
 Wind: 50 TWh/yr

## Medium PV / low wind

Load: 500 TWh/yr  
 PV: 80 TWh/yr  
 Wind: 50 TWh/yr

## High PV / low wind

Load: 500 TWh/yr  
 PV: 200 TWh/yr  
 Wind: 50 TWh/yr



REV 1

# 2x wind (50 to 100 TWh/yr): almost no effect on excess energy

Generated solar PV and wind energy and split into useful and excess for different VRE penetrations

## Low PV / medium wind


Load: 500 TWh/yr  
 PV: 40 TWh/yr  
 Wind: 100 TWh/yr

## Medium PV / medium wind

Load: 500 TWh/yr  
 PV: 80 TWh/yr  
 Wind: 100 TWh/yr

## High PV / medium wind

Load: 500 TWh/yr  
 PV: 200 TWh/yr  
 Wind: 100 TWh/yr



REV 1

# 65% VRE share achievable with almost no excess energy

Generated solar PV and wind energy and split into useful and excess for different VRE penetrations

## Low PV / high wind


Load: 500 TWh/yr  
 PV: 40 TWh/yr  
 Wind: 250 TWh/yr

## Medium PV / high wind

Load: 500 TWh/yr  
 PV: 80 TWh/yr  
 Wind: 250 TWh/yr

## High PV / high wind

Load: 500 TWh/yr  
 PV: 200 TWh/yr  
 Wind: 250 TWh/yr



REV 1

# Electricity surpluses: 65% energy share of solar PV/wind does not cause significant excess electricity

Electricity storage to absorb excess electricity is only required at very high shares of VRE

Excess electricity at very high shares of VRE is mainly driven by solar PV

- Up to a certain energy share, solar PV does not cause excess electricity
- Beyond a threshold, solar PV causes large amounts of excess electricity because of the skewed supply pattern of solar PV (daytime only)
- Wind supply is more volatile, but on average better distributed over the full 24 hours of the day
- Very high shares of wind energy can be achieved without any significant amounts of excess electricity (assuming the wind farms are distributed widely across the country)


For example for 65% VRE share (80 TWh PV and 250 TWh wind, grid-focused distribution, 500 TWh/yr system load), excess electricity is only 1.2% of total solar PV/wind energy produced

Side note: in the 65% VRE case, the entire residual load's fluctuations can be balanced by a conventional fleet that has a fuel-storage capacity of 48 days of the average power output  
(Eskom currently stocks coal on average for the entire fleet for 57 days)

REV 1

# Uniform distribution of wind turbines leads to ~85% lower forecast error for intra-day and ~60% lower for day-ahead

Years considered: 2009-2013



REV 1

# Methodology to derive relative LCOE per pixel

## Relative wind farm cost

Turbine type 5 is approximately 25% more expensive than turbine type 1



Capex: 80% of overall costs  
→ LCOE of turbine type 5 is approximately 20% higher than turbine type 1 (for the same load factor)



Map of relative LCOE (for the same load factor)



## Reference pixel


Turbine 1, load factor ~30%



For every pixel: determine load factor multiplier




## Relative LCOE by multiplying costs with scaled load factors



REV 1


# Large parts of RSA can achieve LCOE well below reference

Relative LCOE across South Africa when installing turbine types 1 to 5




# Large parts of RSA can achieve LCOE well below reference

Relative LCOE across South Africa when installing turbine types 1 to 3 only (i.e. type 3 at 4/5 pixels)



# Large parts of the South African suitable land (entire land mass less exclusion zones) can achieve low wind LCOEs



→ A relative LCOE of 90% or less can be achieved at 44% of the South African land mass (less exclusion zones); 100% benchmark is a high-wind-speed pixel

REV 1

# Results of the aggregation study

## South Africa exhibits extremely good conditions for both wind and solar energy

- Almost the entire country has sufficient resources for profitable wind projects
- High load factors can be achieved almost everywhere (both for solar PV and wind)

## South Africa has more than enough space

- It is possible to generate much more electricity from wind and solar energy than what is needed (solar PV and wind potential is much higher than total demand – today and in future)

## Spatial aggregation brings huge benefits and leverages South Africa's vast land mass

- Aggregation effects: forecast error is reduced significantly for wide wind turbine distribution
- Up to 30% energy share of variable renewable energy (VRE) will not increase short-term ramps in the system significantly if there is a balanced combination of wind & PV in the system
- 50% of wind energy share alone does not significantly increase the 15-minute ramps
- The more distributed wind turbines are being installed, the stronger the aggregation effects (better possibilities of reducing fluctuations)

REV 1

# Contents

1. Introduction
2. Data
3. Methodology
4. Scenarios
- 5. Results**
  - I. Case Study Supply Area Port Elizabeth
  - II. Aggregation Study
  - III. Case Study Curtailment**
6. Conclusions and Outlook

REV 1

# **Curtailment analysis conducted for transmission substations**

**Each transmission substation has a certain rated capacity in MW (maximum evacuation)**

**Each solar PV/wind project has a certain rated/nominal capacity in MW (maximum output)**

**Status quo: solar PV/wind projects can connect to a certain substation up to the point that the sum of the rated solar PV/wind capacity equals the rated capacity of the substation**

**Solar PV and wind projects' power output however is generally not highly correlated**


**This means that the sum of rated solar PV and wind capacity at a substation could be higher than the rated capacity of the substation without running into excess power situation often**

**This effect was analysed and the potential over-installation capacity of solar PV and wind was quantified for all substations across South Africa**

REV 1

# Overcapacity of wind/solar at substation leads to curtailment

Explanation of logic of curtailment at the example of a substation with high simulated solar/wind




REV 1

# 20% additional solar/wind can be installed without curtailment

Statistical analysis of required annual curtailment across all substations (simulating only wind/PV)


Year: 2010 to 2012, no demand considered



REV 1

# 60-70% additional solar/wind can be installed per substation without curtailment if generic load is assumed

Statistical analysis of required annual curtailment across all substations (simulating wind/PV/load)



REV 1

# Curtailment analysis: Results

	Curtailed annual energy per total solar/PV energy	Minimum installable solar/wind power per substation capacity	Average installable solar/wind power per substation capacity	Maximum installable solar/wind power per substation capacity
Only Feed-in	0%	120%	120%	140%
	5%	140%	130%	180%
	10%	150%	170%	200%
Feed-in and load (residual load)	0%	160%	170%	210%
	5%	190%	210%	Not evaluated yet
	10%	210%	240%	Not evaluated yet

REV 1

# Contents

1. Introduction
2. Data
3. Methodology
4. Scenarios
5. Results
6. **Conclusions and Outlook**

# Conclusions for South Africa

- More than 80% of South Africa's land mass has enough wind for high load factors (>30%)
- The magnitude and cost competitiveness of wind power in South Africa is on par with solar PV
- REDZ are a good starting point. When expanding the REDZ further, the wind resource should not be the limiting factor but only environmental considerations
- Short term fluctuations in the aggregated wind power feed-in are significantly reduced by wide spatial distribution
- A share of 50% wind energy in South Africa's electricity supply does not increase the short term gradients if the wind fleet is widely distributed
- Low seasonality of wind and solar PV makes integration easier (no seasonal storage required)
- Distributing wind turbines widely leads to a forecast error improvement of ~85 % for intra-day and of ~60 % for day-ahead compared to putting all wind turbines in one place
- At least 20% additional wind/PV power can be installed per substation without any curtailment of wind/PV power (40% with 5% curtailment) – no load considered, thus conservative

REV 1

# Conclusions for South Africa

**South Africa has perfect conditions to introduce a very large amount of variable renewables into the electricity system**

- Solar and wind energy are very low-cost bulk energy providers in South Africa
- Very low seasonality of both solar and wind supply
- Very wide spread interconnected electricity system that enables spatial aggregation
- South Africa is a very large area country with low population density: space is not a constraint

REV 1

# Outlook

**Further research is required that builds on the results achieved in this study**

- Creation of virtual power plant platforms to balance variable renewables
- Develop forecast model for solar PV and wind feed-in for South Africa
- Develop the concept for reserve provision from variable renewables
- Determine the optimal mix of solar PV and wind for South Africa

**Sector links: South Africa can invest into Power-to-Liquid to make the competitive advantage solar/wind resources an export article for a global CO<sub>2</sub>-neutral-fuels markets**

**Extension of the study to the Southern African Power Pool**

**Data and results will be made publically available**

# Fraunhofer team



**Fraunhofer**  
IWES



Dipl.-Ing. Britta Zimmermann  
Energy Economics and System Design  
Fraunhofer Institute for Windenergy and Energy  
System Technology IWES  
Königstor 59 | 34119 Kassel | Germany  
Phone +49 561 7294-203  
[britta.zimmermann@iwes.fraunhofer.de](mailto:britta.zimmermann@iwes.fraunhofer.de)  
[www.iwes.fraunhofer.de](http://www.iwes.fraunhofer.de)



**Fraunhofer**  
IWES



Dipl.-Ing. Ann-Katrin Gerlach  
Energy Economics and System Design  
Fraunhofer Institute for Windenergy and Energy  
System Technology IWES  
Königstor 59 | 34119 Kassel | Germany  
Phone +49 561 7294-361  
[ann-katrin.gerlach@iwes.fraunhofer.de](mailto:ann-katrin.gerlach@iwes.fraunhofer.de)  
[www.iwes.fraunhofer.de](http://www.iwes.fraunhofer.de)



**Fraunhofer**  
IWES



Dr.-Ing. Stefan Bofinger  
Head of Department  
Energy Economics and System Design  
Fraunhofer Institute for Windenergy and Energy  
System Technology IWES  
Königstor 59 | 34119 Kassel | Germany  
Phone +49 561 7294-371  
[stefan.bofinger@iwes.fraunhofer.de](mailto:stefan.bofinger@iwes.fraunhofer.de)  
[www.iwes.fraunhofer.de](http://www.iwes.fraunhofer.de)

REV 1

# CSIR team



**Crescent Mushwana**  
*Research Group Leader:  
Energy-System Planning and Operation*  
[CMushwana@csir.co.za](mailto:CMushwana@csir.co.za)  
+27 82 310 2142



**Dr Tobias Bischof-Niemz**  
*Head of CSIR's Energy Centre*  
[TBischofNiemz@csir.co.za](mailto:TBischofNiemz@csir.co.za)  
+27 83 403 1108

# Skills exchange



7 guests from South Africa in Germany in August 2015

## Topics

- Collaborative project work
- Workshops:
  - WindPRO course
  - Micro-scale wind modelling workshop
- Presentation of a virtual power plant
- Excursions:
  - 200 m met mast
  - Wind farm

REV 1

**ndza Khensa**

**Ke a leboha**

**Ngiyathokoza**

**Enkosi**

**Thank you**

**Ke a leboga**

**Ndi a livhuha**

**Ngiyabonga**

**Dankie**

REV 1